

Detail & Submittal Sheet


Project: _____
 Specification Reference: _____
 Model Number: _____ Quantity: _____
 Architect: _____
 Contractor: _____
 Distributor: _____
 Approved By: _____
 Date: _____

Construction Specifications:

Titan Series Aluminum cabinets are constructed of non-extruded .063 thick aluminum with grey finish powder coat. All fire-rated cabinets come standard with steel tubs, chrome steel handles and clear acrylic glazing.

To comply with ADA Guidelines, Extinguishers and Cabinets offer handles, brackets and turn-backs according to instructions provided by installer. For ADA compliance follow the specification ordering process dimensions in our catalog. Proper installation in accordance with the ADA Guidelines is the sole responsibility of the installer. For more information please visit the Accessibility Guidelines for Buildings and Facilities website or call them at 1-800-872-2253.

Safeguard fire rated assembly




SPECIFICATION PROCESS: Follow the steps below to specify your cabinet. Options at additional cost.

STEP 1: EXTINGUISHER SIZE: 5 - 5 lb. 1 - 10 lb. 2 - 20 lb.	STEP 4: SERIES: TN - Aluminum Cabinet	<input type="checkbox"/> 010 - Alum. Die Cast Red "Fire" Handle <input type="checkbox"/> 012 - ADA Recessed Handle
STEP 2: CABINET STYLE: 0 - Surface Mounted (S) 1 - Semi-Recessed (SR) 2 - Fully-Recessed (FR)	STEP 5: CABINET TYPE: SG - SAFEGUARD - Fire Rated	STEP 8: GLAZING: <input type="checkbox"/> G11 - Clear Acrylic (Standard) <input type="checkbox"/> G12 - Clear Tempered Glass
STEP 3: DOOR STYLE: 6 - Full Glass (FG) 7 - Full Metal (FM) 8 - Vertical Duo (VD) 9 - Center Duo (CD) 10 - Horizontal Duo (HD)	STEP 6: FINISH (Standard): <input type="checkbox"/> AL - Aluminum Front, Steel Tub	STEP 9: LETTERING: <input type="checkbox"/> 002 - Decal "Pull Firmly" R only <input type="checkbox"/> 003 - Decal "Fire Ext." Sm Vert R/B <input type="checkbox"/> 004 - Decal "Fire Ext." Lrg Vert R/B <input type="checkbox"/> 005 - Decal "Fire Ext." Horiz R/B
	STEP 7: HANDLE OPTIONS: <input type="checkbox"/> 008 - Safety Break Lock	


SAFEGUARD

Typical Semi-Recessed Fire Rated Installation

ONE HOUR FIRE WALL SYSTEM



TWO HOUR FIRE WALL SYSTEM



UL Classified 5/8" Type X gypsum board inserted in the cavity between the two layers. Warnock Hersey has approved the Safeguard Cabinets to be mounted in any face of fire rated steel or wood stud for up to 2 hour rated walls without affecting its fire rating. The above meets the requirement test ASTM-E119-98 with test report WHI-495-1534. MOUNTING INSTRUCTIONS are supplied with each Safeguard cabinet.



✓	Mod. #	Interior Tub Size			Overall Outside Trim		WARNOCK HERSEY LISTED	SAFEGUARD Rough Opening	SAFEGUARD Turnback	Accom. Ext Size	ADA Compliant	
		W	H	D	W	H						Lbs.
Semi-Recessed												
	516-TN-SG	8"	17"	5"	10 3/4"	19 3/4"	10"	19"	4 1/2"	1 3/4"	5	✓
	517-TN-SG	8"	17"	5"	10 3/4"	19 3/4"	10"	19"	4 1/2"	1 3/4"	5	✓
	518-TN-SG	8"	17"	5"	10 3/4"	19 3/4"	10"	19"	4 1/2"	1 3/4"	5	✓
	116-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/4"	25 3/4"	4 1/2"	3"	10	*
	117-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/4"	25 3/4"	4 1/2"	3"	10	*
	118-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/4"	25 3/4"	4 1/2"	3"	10	*
	216-TN-SG	12"	27"	8"	16"	31"	14"	29"	5"	4"	20	*
	217-TN-SG	12"	27"	8"	16"	31"	14"	29"	5"	4"	20	*
	218-TN-SG	12"	27"	8"	16"	31"	14"	29"	5"	4"	20	*
Fully-Recessed												
	526-TN-SG	8"	17"	5"	12"	21"	10"	19"	6"	1/4"	5	✓
	527-TN-SG	8"	17"	5"	12"	21"	10"	19"	6"	1/4"	5	✓
	528-TN-SG	8"	17"	5"	12"	21"	10"	19"	6"	1/4"	5	✓
	126-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/2"	25 3/4"	6 3/4"	1/4"	10	✓
	127-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/2"	25 3/4"	6 3/4"	1/4"	10	✓
	128-TN-SG	9 1/2"	24"	6"	13 1/2"	28 1/2"	11 1/2"	25 3/4"	6 3/4"	1/4"	10	✓
	226-TN-SG	12"	27"	8"	16"	31"	14"	29 1/8"	8 3/4"	1/4"	20	✓
	227-TN-SG	12"	27"	8"	16"	31"	14"	29 1/8"	8 3/4"	1/4"	20	✓
	228-TN-SG	12"	27"	8"	16"	31"	14"	29 1/8"	8 3/4"	1/4"	20	✓

*ADA Recessed Handle required ✓ADA Compliant

Revised 7-2017

